



CITY OF DANVILLE

Carol G. Henley, Director of Purchasing

P.O. Box 3300
Danville, VA 24543

427 Patton Street, Rm 304
Danville, VA 24541

Phone: 434.799.6528 | Fax: 434.799.5102 | Email: purchasing@danvilleva.gov

RFP 24-25-098

"Turnkey Fall Protection System at Public Works Wash Bay"

ADDENDUM No. 2

4/17/2025


Please note the following:

- **Tanker Dimensions**
 - 40' tanker trailer
 - 35' from front access hatch to rear of trailer at steps
 - 2' overhang beyond steps for spray bar
 - 9.5' height from ground to floor of walkway on top of tanker
- **Wash Bay Building Dimensions**
 - 75' long
 - 28' wide
 - 21' to ceiling at center
 - 25' between trusses
 - Center trusses 12" x 5" I-beam, ¼ thick steel
 - 12' opening Roll Up doors
 - Roll Up doors offset, 5' from wall on one side, 10' from wall on other side
 - Floor sump offset, centered on doorway

Note: Suppliers that have submitted an electronic bid will need to resubmit their response to the latest version of the solicitation.

Bidders shall acknowledge receipt of all Addendums.

End of Addendum No. 2



Carol Henley,
Director of Purchasing

Company Name _____ Signature: _____

Address: _____ Name: _____
(Printed)

City _____ State _____ Zip Code _____ Title: _____

Date: _____ E-mail Address _____

Phone No.: _____ Fax No.: _____