



CITY OF DANVILLE

Carol G. Henley, Director of Purchasing

P.O. Box 3300
Danville, VA 24543

427 Patton Street, Rm 304
Danville, VA 24541

Phone: 434.799.6528 | Fax: 434.799.5102 | Email: purchasing@danvilleva.gov

RFP 24-25-110
"New Design Substation 125V Battery System"
ADDENDUM No. 1
5/8/2025

Please note the following questions and answers:

- Should the installation of the battery system be considered in the scope of work or are you only considering the purchase of the equipment?
Just the purchase of equipment. The substation contractor, that will be determined later, will be tasked with installing the battery system.
- Can the City provide a one-line drawing of the DC portion of the station?
[NEW DESIGN DC SYSTEM.pdf](#)
- Is there a preferred manufacturer make and model of the battery?
There is not a particular preferred manufacturer
- Can the City provide the load profile for the battery beyond the "250 amp-hours"?
There will be a steady load of about 20 amps all the time with spikes whenever a breaker operates.

Note: Suppliers that have submitted an electronic bid will need to resubmit their response to the latest version of the solicitation.

Bidders shall acknowledge receipt of all Addendums.

End of Addendum No. 1


Carol Henley,
Director of Purchasing

Company Name _____ Signature: _____

Address: _____ Name: _____
(Printed)

_____ Title: _____
City State Zip Code

Date: _____ E-mail Address _____

Phone No.: _____ Fax No.: _____