



CITY OF DANVILLE

Carol G. Henley, Director of Purchasing

P.O. Box 3300
Danville, VA 24543

427 Patton Street, Rm 304
Danville, VA 24541

Phone: 434.799.6528 | Fax: 434.799.5102 | Email: purchasing@danvilleva.gov

IFB 24-25-102
"Water Treatment Chemicals"
ADDENDUM No. 1
4/24/2025

Please note the following questions and answers:

- Could you please confirm the packaging for the Powdered Activated Carbon?
Powdered activated carbon shall conform to AWWA standard B600-78 or current revision. It shall be shipped in 35 to 100 lb multiwall paper bags with plastic liner to prevent moisture absorbency upon storage and acceptable to the Department of Transportation.
- Can you please provide your current pricing?
[Chemical costs.pdf](#)
- Who are the current suppliers?
See Chemical Costs link above
- What is the packaging size and typical delivery quantity for the liquid aluminum sulfate?
[Chemical Information.pdf](#)
- What percent are you asking for, the packaging size, and typical delivery quantity for the sodium bisulfite?
See Chemical Information link above
- What is the packaging size and typical delivery quantity for the corrosion inhibitor?
See Chemical Information link above
- Please confirm the correct unit price requested for Liquid Aluminum Sulfate, as the specification sheet states the price per dry pound, but the pricing unit is per dry ton.
It shall be priced and paid for on a dry weight basis
- Please confirm the estimated shipment size, payment terms, and delivery days required for Liquid Aluminum Sulfate and Dry Aluminum Sulfate.
See Chemical Information link above
- What is the current price being paid to Brenntag for the Chlorine 150 lb cylinders?
\$1.3490/lb
- How many Chlorine 150 lb cylinders were ordered or used in calendar year 2024?
Ordered 10

- What is the current price being paid to Brenntag for the Caustic Soda 50%?
\$1,224.20/ton
- How many dry tons (or gallons) of Caustic Soda 50% were ordered or used in calendar year 2024?
68,362 gallons
- The "Chemical Information" for Caustic Soda 50% mentions 4,500 gallons per load. DOT weight limits are 3,500 gallons maximum per load. Is that acceptable to the City?
Yes
- Does the City agree to Net 30 payment terms?
Yes

Note: Suppliers that have submitted an electronic bid will need to resubmit their response to the latest version of the solicitation.

Bidders shall acknowledge receipt of all Addendums.

End of Addendum No. 1


Carol Henley,
Director of Purchasing

Company Name _____ Signature: _____

Address: _____ Name: _____
(Printed)

_____ Title: _____

City _____ State _____ Zip Code _____

Date: _____ E-mail Address _____

Phone No.: _____ Fax No.: _____